

**CITY OF BEEVILLE
MCL COLIFORM VIOLATION (TCR22)**

The City of Beeville – PWS ID 0 130001 Water System collected two (2) water samples during July, 2010 that contained coliform bacteria. This water system is required to submit a minimum of twenty (20) routine water samples each month for bacteriological analysis. Five (5) routine samples were coliform – found and one (1) repeat samples were coliform – found for the month and year indicated above.

The Texas Commission on Environmental Quality (TCEQ) sets drinking water standards in Texas and has determined that the presence of total coliform is a possible health concern. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other potentially –harmful bacteria may be present. Coliforms were found in more samples than allowed and this was a warning of potential problems.

For water systems analyzing at least forty (40) samples per month, no more than five percent (5%) of the monthly samples may be positive for total coliform. For systems analyzing fewer than forty (40) samples per month, no more than one (1) sample per month may be positive for total coliform.

If you have questions regarding this matter you may contact Tom Ginter, City Manager at 361-358-4641

**Tomas P. Saenz
City Secretary**

(City Seal)

08/21/2010